


# ReNew100



## Demonstrate Resilient Power System Operation with 100% Non-Synchronous Generation

Ulrich Muenz

Siemens Corporate Technology, Princeton, NJ

# 100% renewable, non-synchronous generation poses big challenges to power system operation and planning



		
Challenge	HW Solution	SW Solution
Power balance	Storage	Generation & demand management
Power transfer	Power lines	Nodal prices, OPF
Dynamic security	?	Dynamic Security Optimization
Protection	Breakers	Adaptive protection


ReNew 100





# ReNew100: Demonstrate N-1 Secure Power System Operation with 100% Non-Synchronous Generation

**SIEMENS**  
*Ingenuity for life*

Dynamic Security Optimization




Minimize required grid-forming ratio




Model Calibration using HECO PMU data


# Modification of Hawai'i Island's power system leads to a power system with various 100% non-synchronous generation cases



Generation	Today	Planned	Extension	Total
Wind	30MW		20MW	50MW
Centralized Solar		2x30MW	2x30MW	120MW
Distributed Solar	70MW		40MW	110MW
Centralized Battery		2x30MW	2x30MW	120MW
Distributed Battery			40MW	40MW
Synchr. Renewable	90MW			90MW
Conventional	160MW			160MW



# We develop consistent models across different simulation tools



## Project status


- 6 area, 10 generator model implemented
- extension to full model on-going

## Compared models

- PSS®E (RMS)
- PSS®Sincal (RMS)
- PSS®Sincal (EMT)
- SimScape SimPower Systems (EMT)

## Key observations from 6a/10g model

- **Very good match of key dynamics** between all models in both RMS and EMT
  - Eigenmodes
  - Overshoot
- **60 Hz oscillation** occurs in EMT simulation due to DC part of the stator dynamics.



# ReNew100: Demonstrate N-1 Secure Power System Operation with 100% Non-Synchronous Generation

**SIEMENS**  
Ingenuity for life

## Dynamic Security Optimization

Operator  
Support System

Dynamic Security Optimization

**SIGUARD**  
Dynamic Security Assessment

EMS



Spectrum Power EMS

State Estimator


AGC

Minimize required grid-forming ratio

## Consistent modeling across different tools





Power System




## Model Calibration using HECO PMU data

### Schematic of model calibration methodology



Ensemble Kalman Filter based  
model calibration algorithm



Model validation against  
PMU measurements




# We calibrate generator models using PMU data from HELCO

## Challenge

- Accurate model required for Dynamic Security Assessment and Optimization
- Planning models used for generator plants may have incorrect parameters




## Our Approach

- Calibrate power system model using PMU data from HELCO
- Generator model calibration based on Ensemble Kalman Filter (EnKF)
- PMU measurements will be used as event playback




# ReNew100: Demonstrate N-1 Secure Power System Operation with 100% Non-Synchronous Generation

**SIEMENS**  
Ingenuity for life






# We develop fast optimization algorithms for oscillation and overshoot damping




## Project status

- Development of linear model started
- Optimization will developed starting from prior project's work

## High risk of blackout



## Resilient operation



From small to large

- 203x USA (1000GW)
- 202x Puerto Rico (3GW)
- 2022 Hawaii (180MW)
- 2021 NSGB (20MW)
- ✓ 2018 Galapagos (1MW)
- ✓ 2017 IREN2 (0.1MW)


# Detailed power plant models are optimized

❖ 19 states per generator

❖ 10 tunable controller parameters per generator




## Decomposition of Generator




PSS



Automatic Voltage Regulator  
+ Exciter Model




Turbine + Governor



# Application example shows significant increase of power oscillation damping for IEEE39 benchmark model

## IEEE 39 bus benchmark model



IEEE 39 bus model from<sup>[3]</sup>  
with component models  
from<sup>[4,5]</sup> and PSS from<sup>[2]</sup>


add'l HVDC line

**Optimization  
Problem  
Characterization**


216 states

128 controller parameters

### Initial Parameters



### Optimized Parameters



[2] P. Kundhur, Power System Stability and Control, McGraw-Hill, 1993.

[3] A. Moeini, I. Kamwa, P. Brunelle, G. Sybille, "Open Data IEEE Test Systems Implemented in SimpowerSystems for Education and Research in Power Grid Dynamics and Control," Power Engineering Conference (UPEC), 2015 50th International Universities, 1-4 Sept. 2015, Staffordshire University, UK. (<https://www.mathworks.com/matlabcentral/fileexchange/54771-10-machine-new-england-power-system-ieee-benchmark>)







[4] IEEE committee report, "Dynamic models for steam and hydro turbines in power system studies," IEEE Transactions on Power Apparatus and Systems, Vol. PAS-92, No. 6, 1973, pp. 1904-1915.

[5] "Recommended Practice for Excitation System Models for Power System Stability Studies," IEEE® Standard 421.5-1992, August, 1992.



# ReNew100: Demonstrate N-1 Secure Power System Operation with 100% Non-Synchronous Generation

**SIEMENS**  
*Ingenuity for life*



# We benchmark grid-forming and grid-supporting inverter control structures to minimize grid-forming to grid-supporting ratio

## Challenge

- Minimize required ratio between grid-forming inverters and grid-following inverter for N-1 secure operation


## Our Approach

- Benchmark grid-forming and grid-following inverter controllers
- Validate N-1 secure operation in PSS®Sincal


## Project status

- Development of PSS®Sincal model started


### Direct Voltage Control



### Voltage and Current controls




### Voltage and Current control with voltage feed-forward



# ReNew100: Demonstrate N-1 Secure Power System Operation with 100% Non-Synchronous Generation

**SIEMENS**  
Ingenuity for life

## Dynamic Security Optimization



Operator  
Support System

## Dynamic Security Optimization

## SIGUARD Dynamic Security Assessment

## Spectrum Power EMS


State Estimator

AGC


EMS

## Minimize required grid-forming ratio


Compare grid-forming inverter controls to achieve N-1 resilient operation with minimal ratio between grid-forming and grid-supporting inverters





Voltage and Current controls




Voltage and Current control with voltage feed-forward



## Consistent modeling across different tools







Power System



## Model Calibration using HECO PMU data

### Schematic of model calibration methodology



Ensemble Kalman Filter based model calibration algorithm

Model validation against PMU measurements



## Contact page



### **Ulrich Muenz**

Head of Research Group

Autonomous Systems and Control / US / CT RDA FOA ASY-US

755 College Road East  
Princeton, NJ 08540

USA

Mobile: +1 609 216 0170

E-mail: [ulrich.muenz@siemens.com](mailto:ulrich.muenz@siemens.com)

**siemens.com**